

Table 3 — Minimum requirements for classification of strongroom doors and strongrooms into resistance grades

Resistance grade	Tool attack test (Clause 7)	Locks ^a		Additional requirements for EX designation (optional) (Clause 9)	Additional requirements for CD designation (optional) (Clause 11)
		Quantity	Class according to EN 1300		
	Resistance value for complete access			Post-detonation resistance value ^c	Resistance value ^c
	RU			RU	RU
0	30	1	A	b	d
I	50	1	A	b	d
II	80	1	A	4	d
III	120	1	B	6	d
IV	180	2	B	9	d
V	270	2	B	14	d
VI	400	2	C	20	d
VII	600	2	C	30	d
VIII	825	2	C	41	10 000
IX	1 050	2	C	53	10 000
X	1 350	2	C	68	10 000
XI	2 000	3	C or	100	10 000
		2	D		
XII	3 000	3	C or	150	10 000
		2	D		
XIII	4 500	2	D	225	10 000

^a Not applicable for classification of strongrooms without a door.
^b EX designation is not permitted for resistance grades 0 and I.
^c Resistance value for complete access.
^d CD designation is not permitted for resistance grades 0 to VII.